

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No:** 7272-1130:128 Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** \*Honeywell International Inc., 1500 W. Dundee Rd., Arlington Heights IL 60004-1472  
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

**DESIGN:** Models TC804C-1001 and TC804C-1019 photoelectric smoke detectors. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as photoelectric smoke detectors for use with separately listed compatible fire alarm control units and Model 14506587-001 base.

**NOTE:** Formerly 7257-1130:128

**XLF:** 7272-0087:131

\*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 14, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager